



SECTION

DOOR REF No _____

NOTES

IT IS THE CLIENTS RESPONSIBILITY TO ENSURE THAT THE STRUCTURE IS CAPABLE OF ACCEPTING THE FIXINGS SHOWN AND SUPPORTING THE DOOR / PRODUCT WEIGHT WHILST AT REST AND DURING OPERATION.

APPROX. CURTAIN/ BOX WT. = Kg.

BOLTON GATE CO. LTD. RECOMMEND THAT FULL ACCESS TO THE SHUTTER BOX TO BE PROVIDED ACROSS THE OPENING FOR MAINTENANCE / REPLACEMENT PURPOSES. IF FULL ACCESS IS NOT PROVIDED THEN BOLTON GATE CO LTD. WILL NOT ACCEPT ANY CHARGES ASSOCIATED WITH GAINING ACCESS TO FACILITATE MAINTENANCE OR REPLACEMENT OF SHUTTER COMPONENTS.

ALL NECESSARY FIRE RESISTANT INFILL REQUIRED IN THE VICINITY OF THE CURTAIN TO BE SUPPLIED & INSTALLED BY OTHERS.

ELECTRICAL OPERATION BY 24 VOLT DC TUBULAR MOTORS, CLIENT TO PROVIDE A 240 VOLT 1 PH SUPPLY, TERMINATED AT A 3 AMP FUSED SPUR, ON A MAINTAINED CIRCUIT TO BE POSITIONED WITHIN ONE METRE OF CONTROL PANEL BY OTHERS.

GROUP CONTROL PANEL MOUNTED AT HIGH LEVEL ADJACENT TO THE HEAD BOX, INCORPORATING AN INTEGRAL BATTERY PACK, ACCESS FOR MAINTENANCE MUST BE AVAILABLE.

THE CURTAINS DESCEND UNDER THE POWER OF GRAVITY UPON RECEIPT OF A SIGNAL FROM THE FIRE-ALARM PANEL, AND AUTOMATICALLY RETRACT WHEN THE SIGNAL IS REMOVED.

THE FOLLOWING WORKS ARE TO BE COMPLETED BY OTHERS PRIOR TO THE COMMENCEMENT OF OUR WORKS:

- a) PROVISION OF A 240 VOLT SINGLE PHASE MAINS SUPPLY & FUSED SPUR WITHIN ONE METRE OF CONTROL PANEL.
- b) PROVISION OF A NORMALLY CLOSED CONTACT (FROM FIRE ALARM) TERMINATED IN A LOCAL JUNCTION BOX (WITHIN 500mm OF CONTROL PANEL).

ALL MAINS SUPPLIES MUST BE INSTALLED AND LIVE PRIOR TO BOLTON GATE CO. ARRIVAL ON SITE, OTHERWISE RETURN VISITS WILL BE NECESSARY AT ADDITIONAL COST.

FINISH: ALL METALWORK STANDARD GALV.



Bolton Gate Co. Limited
 Waterloo Street
 Bolton. BL1 2SP
 Telephone: 01204 871000
 Facsimile: 01204 871049

TITLE	GENERAL ARRANGEMENT OF ROLLING SMOKE CURTAIN	
SITE		
DATE	REVISION	

C		F	DRAWN:	WORKS ORDER No
B		E	DATE:	
A		D	CHECKED:	DRAWING NUMBER
REF	DATE	REF	SCALE:	
